



## environmental affairs

Department:  
Environmental Affairs  
REPUBLIC OF SOUTH AFRICA

Private Bag X 447· PRETORIA · 0001· Environment House · 473 Steve Biko Road, Arcadia, PRETORIA  
Tel (+ 27 12) 399 9372

**DEA Reference:** 14/12/16/3/3/2/1103

**Enquiries:** Ms Thabile Sangweni

**Telephone:** (012) 399 9409 **E-mail:** TSangweni@environment.gov.za

Mr Lance Blaine  
Red Cap Impofu West (Pty) Ltd  
Unit B2  
Mainstream Centre  
**CAPE TOWN**  
7806

Telephone Number: (021) 790 1392  
Email Address: Lance@red-cap.co.za

### **PER E-MAIL / MAIL**

Dear Mr Blaine

### **APPLICATION FOR ENVIRONMENTAL AUTHORISATION IN TERMS OF THE NATIONAL ENVIRONMENTAL MANAGEMENT ACT, 1998: FOR THE 174MW IMPOFU WEST WIND ENERGY FACILITY AND ITS ASSOCIATED INFRASTRUCTURE NEAR OYSTER BAY WITHIN THE KOUGA LOCAL MUNICIPALITY IN THE EASTERN CAPE PROVINCE**

With reference to the above application, please be advised that the Department has decided to grant an Environmental Authorisation (EA) to you. The Environmental Authorisation and reasons for the decision are attached herewith.

In terms of Regulation 4(2) of the National Environmental Management Act (NEMA): the Environmental Impact Assessment Regulations, 2014, as amended (the EIA Regulations), you are instructed to notify all registered interested and affected parties (I&APs), in writing within 14 (fourteen) days of the date of this EA, of the Department's decision as well as the provisions regarding the submission of appeals that are contained in the Regulations.

In terms of the Promotion of Administrative Justice Act, 2000 (Act No 3 of 2000), you are entitled to the right to fair, lawful and reasonable administrative action; and to written reasons for administrative action that affects you negatively. Further your attention is drawn to the provisions of the Protection of Personal Information Act, 2013 (Act no. 4 of 2013) which stipulates that the Department should conduct itself in a responsible manner when collecting, processing, storing and sharing an individual or another entity's personal information by holding the Department accountable should the Department abuses or compromises your personal information in any way.

Your attention is drawn to Chapter 2 of National Environmental Management Act, 1998 (Act No. 107 of 1998) National Appeal Regulations published under Government Notice R993 in Government Gazette No. 38303 dated 08 December 2014 (National Appeal Regulations, 2014), which prescribe the appeal procedure to be followed. Kindly include a copy of this document (National Appeal Regulations, 2014) with the letter of notification to interested and affected parties in this matter.

*M.S*

Should any person wish to lodge an appeal against this decision, he/she must submit the appeal to the appeal administrator, and a copy of the appeal to the applicant, any registered interested and affected party, and any organ of state with interest in the matter within 20 days from the date that the notification of the decision was sent to the registered interested and affected parties by the applicant; or the date that the notification of the decision was sent to the applicant by the Department, whichever is applicable.

**Appeals must be submitted in writing in the prescribed form to:**

The Director: Appeals and Legal Review of this Department at the below mentioned addresses.

By email: [appealsdirector@environment.gov.za](mailto:appealsdirector@environment.gov.za);

By hand: Environment House  
473 Steve Biko Road  
Arcadia  
Pretoria  
0083; or

By post: Private Bag X447  
Pretoria  
0001

Please note that in terms of Section 43(7) of the NEMA, the lodging of an appeal will suspend the environmental authorisation or any provision or condition attached thereto. In the instance where an appeal is lodged, you may not commence with any activity authorised in the EA until such time that the appeal is finalised.

To obtain the prescribed appeal form and for guidance on the submission of appeals, please visit the Department's website at [https://www.environment.gov.za/documents/forms#legal\\_authorisations](https://www.environment.gov.za/documents/forms#legal_authorisations) or request a copy of the documents at [appealsdirector@environment.gov.za](mailto:appealsdirector@environment.gov.za).

Yours faithfully



**Mr Sabelo Malaza**  
**Chief Director: Integrated Environmental Authorisations**  
**Department of Environmental Affairs**

Date: 23/09/2019

cc: K Jones	Aurecon SA	Email: <a href="mailto:Kirsten.Jones@aurecongroup.com">Kirsten.Jones@aurecongroup.com</a>
-------------	------------	---

M-S



## environmental affairs

Department:  
Environmental Affairs  
REPUBLIC OF SOUTH AFRICA

# Environmental Authorisation

In terms of Regulation 25 of the Environmental Impact Assessment Regulations, 2014

The 174MW Impofu West Wind Energy Facility (WEF) and its associated infrastructure near Oyster Bay  
within the Kouga Local Municipality in the Eastern Cape Province

Sarah Baartman District Municipality

<b>Authorisation register number:</b>	14/12/16/3/3/2/1103
<b>Last amended:</b>	First issue
<b>Holder of authorisation:</b>	Red Cap Impofu West (Pty) Ltd
<b>Location of activity:</b>	Erf 1/717 of Farm Lange Fontein; Erf 818; Erf 1/676 of Farm Klip Rug; Erf 2/676 of Farm Klip Rug; Erf 3/676 of Farm Klip Rug; Erf RE/675 of Farm Vergaaderings Kraal; RE2/678; RE/678; Kouga Local Municipality; Sarah Baartman District Municipality; Eastern Cape Province.

This authorisation does not negate the holder of the authorisation's responsibility to comply with any other statutory requirements that may be applicable to the undertaking of the activity.

MS

## Decision

The Department is satisfied, on the basis of information available to it and subject to compliance with the conditions of this environmental authorisation, that the applicant should be authorised to undertake the activities specified below.

Non-compliance with a condition of this environmental authorisation may result in criminal prosecution or other actions provided for in the National Environmental Management Act, 1998 and the EIA regulations.

Details regarding the basis on which the Department reached this decision are set out in Annexure 1.

## Activities authorised

By virtue of the powers conferred on it by the National Environmental Management Act, 1998 (Act No. 107 of 1998) and the Environmental Impact Assessment Regulations, 2014 the Department hereby authorises –

### **RED CAP IMPOFU WEST (PTY) LTD**

(hereafter referred to as the **holder of the authorisation**)

with the following contact details –

Mr Lance Blaine  
Unit B2  
Mainstream Centre  
Hout Bay  
**CAPE TOWN**  
7806

Telephone Number: (021) 790 1392  
Cell phone Number: (083) 235 6737  
E-mail Address: Lance@red-cap.co.za

to undertake the following activities (hereafter referred to as “the activity”) indicated in Listing Notice 1, Listing Notice 2 and Listing Notice 3 of the EIA Regulations, 2014 as amended:

Listing Notice 1 of the EIA Regulations of 2014, as amended	Activity description
<p><u>Item 11:</u></p> <p><i>“The development of facilities or infrastructure for the transmission and distribution of electricity –</i></p> <p><i>(i) outside urban areas or industrial complexes with a capacity of more than 33 but less than 275 kV.”</i></p>	<p>The site is currently zoned as agricultural land and falls outside the urban area. Underground and overhead medium voltage powerlines (33kV or lower) and 132kV substations (including control, operation, workshop, storage buildings / areas) will be required for the Impofu Wind Farms.</p>
<p><u>Item 12:</u></p> <p><i>“The development of—</i></p> <p><i>(ii) infrastructure or structures with a physical footprint of 100 square metres or more; where such development occurs—</i></p> <p><i>(a) within a watercourse;</i></p> <p><i>(c) if no development setback exists, within 32 metres of a watercourse, measured from the edge of a watercourse.”</i></p>	<p>The proposed site is characterised by drainage lines and watercourses scattered across the site. One or more roads and/or powerlines are likely to cross these watercourses or drainage lines or be within 32m thereof.</p> <p>Where feasible, the development layout has however made use of as many existing farm tracks as possible and tries to minimise any new impacts on these watercourses and drainage lines.</p>
<p><u>Item 19:</u></p> <p><i>“The infilling or depositing of any material of more than 10 cubic metres into, or the dredging, excavation, removal or moving of soil, sand, shells, shell grit, pebbles or rock of more than 10 cubic metres from</i></p> <p><i>(i) a watercourse.”</i></p>	<p>A number of internal roads and access roads are likely to cross watercourses and drainage lines. The infilling or depositing of any material of more than 10m<sup>3</sup> into a watercourse may be triggered with the construction of internal service roads or underground cables crossing the drainage lines.</p>
<p><u>Item 24:</u></p> <p><i>“The development of a road—</i></p>	<p>Permanent roads of approximately 6 m wide will be needed with side drains on one or both sides where necessary. During construction roads of</p>

<p><i>(ii) with a reserve wider than 13,5 meters, or where no reserve exists where the road is wider than 8 metres."</i></p>	<p>approximately 8 m in width, with a reserve / buffer of approximately 12 m may also be temporarily required.</p>
<p><u>Item 27:</u>  <i>"The clearance of an area of 1 hectares or more, but less than 20 hectares of indigenous vegetation, except where such clearance of indigenous vegetation is required for-</i>  <i>(i) the undertaking of a linear activity."</i></p>	<p>Although the footprint of all site infrastructure is located outside the highly sensitive No-Go areas and largely within transformed areas, there is the likelihood for some natural but degraded areas to be impacted. This is less than 20 ha. Also note that much of the infrastructure is linear (roads and cable, or overhead lines) which reduces further the total footprint in this regard.</p>
<p><u>Item 28:</u>  <i>"Residential, mixed, retail, commercial, industrial or institutional developments where such land was used for agriculture, game farming, equestrian purposes or afforestation on or after 01 April 1998 and where such development:</i>  <i>(ii) will occur outside an urban area, where the total land to be developed is bigger than 1 hectare."</i></p>	<p>The proposed site is zoned as agricultural land and will continue to be used for agricultural purposes should the proposed Impofu Wind Farms receive environmental authorisations.</p>
<p><u>Item 56:</u>  <i>"The widening of a road by more than 6m, or lengthening of a road by more than 1km-</i>  <i>(ii) where no reserve exists, where the existing road is wider than 8 metres."</i></p>	<p>Existing roads would be used as far as practically possible and feasible, but may likely require widening up to 6m and/or lengthening by more than 1km, to accommodate the movement of heavy vehicles and cable trenching activities. Access roads of approximately 8m in width, with a reserve / buffer of approximately 12m may also be required during construction.</p>

<p><b>Listing Notice 2 of the EIA Regulations of 2014, as amended</b></p>	
<p><u>Item 1:</u>  <i>“The development of facilities or infrastructure for the generation of electricity from a renewable resource where the electricity output is 20 megawatts or more.”</i></p>	<p>The proposed Impofu Wind Farms would each have a maximum generation capacity of up to 198MW.</p>
<p><u>Item 4:</u>  <i>“The development of a road wider than 4 metres with a reserve less than 13, 5 metres.</i>  <i>(a) In the Eastern Cape:</i>  <i>(i) Outside urban areas</i>  <i>(gg) Areas within 10 km from national parks or world heritage sites or 5 km from any protected area identified in terms of NEMPAA or from the core areas of a biosphere reserve.”</i></p>	<p>Access roads of approximately 8m in width, with a reserve / buffer of approximately 12m may also be required during construction.</p> <p>Although the formally protected Huisclip Nature Reserve is located more than 5km from the site, the Greater Kromme Stewardship Initiative is proactively identifying areas suitable for declaration as protected areas. Existing ecological corridors that could be represented by future protected areas have been included in the assessment to account for this potential listed activity.</p>
<p><b>Listing Notice 3 of the EIA Regulations of 2014, as amended</b></p>	
<p><u>Item 14:</u>  <i>The development of-</i>  <i>(ii) infrastructure or structures with a physical footprint of 10 square metres or more;</i>  <i>where such development occurs-</i>  <i>(a) within a watercourse;</i>  <i>(c) if no development setback has been adopted, within 32 metres of a watercourse, measured from the edge of a watercourse;</i>  <i>(a) In the Eastern Cape:</i>  <i>i. Outside urban areas:</i></p>	<p>Access roads of approximately 8 m in width will be developed, with a reserve / buffer of approximately 12 m required during construction. These internal roads will cross two watercourses (wetlands) as identified by the aquatic specialist.</p> <p>Although the formally protected Huisclip Nature Reserve (which is also a core area of the Garden Route Biosphere Reserve) is located more than 5 km from the site, the Greater Kromme Stewardship Initiative is proactively identifying areas suitable for</p>

<p><i>(hh) Areas within 10 kilometres from national parks or world heritage sites or 5 kilometres from any other protected area identified in terms of NEMPAA or from the core area of a biosphere reserve."</i></p>	<p>declaration as protected areas. Existing ecological corridors that could be represented by future protected areas have been included in the assessment to account for this potential listed activity.</p>
<p><u>Item 18:</u>  <i>"The widening of a road by more than 4 meters, or the lengthening of a road by more than 1 kilometre:</i>  <i>a) In the Eastern Cape:</i>  <i>i. Outside Urban Areas</i>  <i>(gg) Areas within 10 kilometers from national parks or world heritage sites or 5 kilometers from any other protected area identified in terms of NEMPAA or from the core area of a biosphere reserve;</i>  <i>(ii) Areas within 100 metres from the edge of a watercourse where no such setback line has been determined;</i>  <i>(kk) A watercourse."</i></p>	<p>Existing roads would be used as far as practically possible and feasible, but may likely require widening up to 6m and/or lengthening by more than 1km, to accommodate the movement of heavy vehicles and cable trenching activities. Access roads of approximately 8m in width, with a reserve / buffer of approximately 12m may also be required.</p> <p>Some of these roads may be located within 100m of watercourses (drainage lines) on the site, and some crossings may be required.</p> <p>Although the formally protected Huisclip Nature Reserve (which is also a core area of the Garden Route Biosphere Reserve) is located more than 5 km from the site, the Greater Kromme Stewardship Initiative is proactively identifying areas suitable for declaration as protected areas. Existing ecological corridors that could be represented by future protected areas have been included in the assessment to account for this potential listed activity.</p>

as described in the Environmental Impact Assessment Report (EIAr) dated June 2019 at:

Impofu West (WEF preferred site)	Latitude	Longitude
	34° 03' 44.723" S	24° 31' 59.118" E
	34° 04' 14.488" S	24° 34' 12.862" E
	34° 04' 04.710" S	24° 35' 50.402" E
	34° 06' 06.361" S	24° 33' 19.560" E

	34° 07' 41.374" S	24° 30' 31.508" E
	34° 04' 29.260" S	24° 33' 04.189" E
	34° 03' 37.748" S	24° 35' 02.723" E
	34° 06' 19.938" S	24° 34' 21.559" E
	34° 07' 29.626" S	24° 31' 29.109" E
	34° 05' 08.355" S	24° 31' 25.400" E

- for the proposed 174MW Impofu West WEF and its associated infrastructure near Oyster Bay within the Kouga Local Municipality in the Eastern Cape Province, hereafter referred to as "the property".

The facility will comprise the following:

- Turbines: Up to 29 turbines with a hub height from 90m to 120m, and rotor diameter of up to 150m. The minimum tip height (ground clearance) will be at least 30m;
- Crane hard stands: One per turbine, with a permanent hardstand 50m X 30m which will remain for maintenance purposes;
- Access and internal roads: The internal gravel roads will be approximately 6m wide with potential side drains. Some sections of these roads would need to be temporarily widened up to 12m during construction;
- On-site substation: Each substation is approximately 150 X 75m (11 250m<sup>2</sup>) which will occupy the area for operation and maintenance;
- Cables: Each turbine will be connected to the substation via medium voltage cables (~ 33kV lines). Where feasible the cables will be laid underground in trenches, generally running alongside existing or proposed new internal roads. Where burying of cables is not possible due to technical, geological, environmental or topographical constraints, then overhead powerlines will be erected;
- Permanent Operational & Maintenance (O&M) buildings: The substation area would house buildings or areas for control, operation, workshop and storage; and,
- Laydown area and site camp: The temporary laydown areas will be approximately 145 000m<sup>2</sup> and the permanent area, 43 500m<sup>2</sup> and the temporary site camp of approximately 15,000m<sup>2</sup>. An additional 1,000m<sup>2</sup> will be temporarily required for concrete batching.

Technical details of the WEF:

Component	Description/ Dimensions
Location of the site	Approximately 14km north-west of Oyster Bay in the Eastern Cape Province

SG Codes	<p>C03400000000071700001</p> <p>C03400000000081800000</p> <p>C03400000000067600001</p> <p>C03400000000067600002</p> <p>C03400000000067600003</p> <p>C03400000000067500000</p> <p>C03400000000067800002</p> <p>C03400000000067800000</p>
Site access	The site will be accessed from the DR01765, the MN50032, DR01774 and DR01764. Existing roads will be utilised and upgraded as far as possible.
Export capacity	Up to 174MW
Proposed technology	Wind turbines
Number of Turbines	Up to 29
Hub height from ground level	90m-120m
Rotor diameter	Up to 150m
Surface area to be covered (including associated infrastructure such as roads)	<p>Total approximately 455,750 m<sup>2</sup> comprising of:</p> <p>Temporary construction laydown areas (turbine hardstand areas): 29 x 100 x 50 m = 145,000 m<sup>2</sup>;</p> <p>Temporary site camp areas: 15,000 m<sup>2</sup> and batching plant area of approximately 1,000 m<sup>2</sup>;</p> <p>Permanent upgrade of existing tracks and roads and construction of new roads covering an area of approximately 240,000 m<sup>2</sup>;</p> <p>Permanent laydown areas of approximately 29 x 50 x 30 m = 43,500 m<sup>2</sup>; and</p> <p>Impofu West Substation approximately 150 x 75 m = 11,250 m<sup>2</sup>.</p> <p>Temporary areas will be rehabilitated after construction.</p>
Width and length of internal roads	<p>Internal road network is ±24 km in length, here existing roads and tracks will be used as far as practicable.</p> <p>Permanent roads will be approximately 6 m wide. Some sections of these roads would need to be temporarily widened up to 12 m during construction.</p>

## Conditions of this Environmental Authorisation

### Scope of authorisation

1. The construction of the Impofu West Energy Facility and its associated infrastructure with a maximum output capacity of 174MW as described above is hereby approved.
2. Authorisation of the activity is subject to the conditions contained in this environmental authorisation, which form part of the environmental authorisation and are binding on the holder of the authorisation.
3. The holder of the authorisation is responsible for ensuring compliance with the conditions contained in this environmental authorisation. This includes any person acting on the holder's behalf, including but not limited to, an agent, servant, contractor, sub-contractor, employee, consultant or person rendering a service to the holder of the authorisation.
4. The activities authorised must only be carried out at the property as described above.
5. Any changes to, or deviations from, the project description set out in this environmental authorisation must be approved, in writing, by the Department before such changes or deviations may be effected. In assessing whether to grant such approval or not, the Department may request such information as it deems necessary to evaluate the significance and impacts of such changes or deviations and it may be necessary for the holder of the authorisation to apply for further environmental authorisation in terms of the regulations.
6. The holder of an environmental authorisation must apply for an amendment of the environmental authorisation with the competent authority for any alienation, transfer or change of ownership rights in the property on which the activity is to take place.
7. This activity must commence within a period of five (05) years from the date of issue of this environmental authorisation. If commencement of the activity does not occur within that period, the authorisation lapses and a new application for environmental authorisation must be made in order for the activity to be undertaken.
8. Construction must be completed within five (05) years of the commencement of the activity on site.
9. Commencement with one activity listed in terms of this environmental authorisation constitutes commencement of all authorised activities.

### **Notification of authorisation and right to appeal**

10. The holder of the authorisation must notify every registered interested and affected party, in writing and within 14 (fourteen) calendar days of the date of this Environmental Authorisation, of the decision to authorise the activity.
11. The notification referred to must –
  - 11.1. specify the date on which the authorisation was issued;
  - 11.2. inform the interested and affected party of the appeal procedure provided for in the National Appeal Regulations, 2014;
  - 11.3. advise the interested and affected party that a copy of the authorisation will be furnished on request; and
  - 11.4. give the reasons of the Competent Authority for the decision.

### **Commencement of the activity**

12. The authorised activity must not commence until the period for the submission of appeals has lapsed as per the National Appeal Regulations, 2014, and no appeal has been lodged against the decision. In terms of Section 43(7), an appeal under Section 43 of the National Environmental Management Act, Act No. 107 of 1998, as amended will suspend the Environmental Authorisation or any provision or condition attached thereto. In the instance where an appeal is lodged you may not commence with the activity until such time that the appeal has been finalised.

### **Management of the activity**

13. A copy of the final site layout map must be made available for comments by registered Interested and Affected Parties and the holder of this environmental authorisation must consider such comments. Once amended, the final development layout map must be submitted to the Department for written approval prior to commencement of the activity. All available biodiversity information must be used in the finalisation of the layout map. Existing infrastructure must be used as far as possible e.g. roads. The layout map must indicate the following:
  - 13.1. Cable routes (where they are not along internal roads);
  - 13.2. Position of wind turbines and associated infrastructure;
  - 13.3. Internal roads indicating width;
  - 13.4. Wetlands, drainage lines, rivers, stream and water crossing of roads and cables;

- 13.5. All sensitive features e.g. Critical Biodiversity Areas, Ecological Support Areas, heritage sites, wetlands, pans and drainage channels that will be affected by the facility and associated infrastructure;
  - 13.6. Substation(s) inverters and/or transformer(s) sites including their entire footprint;
  - 13.7. Connection routes (including pylon positions) to the distribution/transmission network;
  - 13.8. All existing infrastructure on the site, such as roads;
  - 13.9. Soil heaps (temporary for topsoil and subsoil and permanently for excess material);
  - 13.10. Buildings, including accommodation; and,
  - 13.11. All "no-go" and buffer areas.
14. Furthermore, a shapefile of the approved development layout/footprint must be submitted to this Department within two months from the date of this decision. The shapefile must be created using the Hartebeesthoek 94 Datum and the data should be in Decimal Degree Format using the WGS 84 Spheroid. The shapefile must include at a minimum the following extensions i.e. .shp; .shx; .dbf; .prj; and, .xml (Metadata file). If specific symbology was assigned to the file, then the .avl and/or the .lyr file must also be included. Data must be mapped at a scale of 1:10 000 (please specify if an alternative scale was used). The metadata must include a description of the base data used for digitizing. The shapefile must be submitted in a zip file using the EIA application reference number as the title.

The shape file must be submitted to:

**Postal Address:**

Department of Environmental Affairs  
Private Bag X447  
Pretoria  
0001

**Physical address:**

Department of Environmental Affairs  
Environment House  
473 Steve Biko Road  
Arcadia  
Pretoria

For Attention: Mr Muhammad Essop

---

*M.S*

Integrated Environmental Authorisations

Strategic Infrastructure Developments

Telephone Number: (012) 399 9406

Email Address: [MEssop@environment.gov.za](mailto:MEssop@environment.gov.za)

15. The Environmental Management Programme (EMPr) submitted as part of the EIAr is not approved and must be amended to include measures as dictated by the final site lay-out map and micro-siting, and the provisions of this environmental authorisation. The EMPr must be made available for comments by registered Interested and Affected Parties and the holder of this environmental authorisation must consider such comments. Once amended, the final EMPr must be submitted to the Department for written approval prior to commencement of the activity. Once approved the EMPr must be implemented and adhered to.
  16. The EMPr amendment must include the following:
    - 16.1. The requirements and conditions of this authorisation.
    - 16.2. All recommendations and mitigation measures recorded in the EIAr.
    - 16.3. All mitigation measures as listed in the specialist reports must be included in the EMPr and implemented.
    - 16.4. The final site layout map.
    - 16.5. An alien invasive management plan to be implemented during construction and operation of the facility. The plan must include mitigation measures to reduce the invasion of alien species and ensure that the continuous monitoring and removal of alien species is undertaken.
    - 16.6. A plant rescue and protection plan which allows for the maximum transplant of conservation important species from areas to be transformed. This plan must be compiled by a vegetation specialist familiar with the site in consultation with the ECO and be implemented prior to commencement of the construction phase.
    - 16.7. A re-vegetation and habitat rehabilitation plan to be implemented during the construction and operation of the facility. Restoration must be undertaken as soon as possible after completion of construction activities to reduce the amount of habitat converted at any one time and to speed up the recovery to natural habitats.
    - 16.8. A traffic management plan for the site access roads to ensure that no hazards would result from the increased truck traffic and that traffic flow would not be adversely impacted. This plan must include measures to minimize impacts on local commuters e.g. limiting construction vehicles travelling on public roadways during the morning and late afternoon commute time and avoid using roads through densely populated built-up areas so as not to disturb existing retail and commercial operations.
-

- 16.9. A construction and operational avifauna and bat monitoring plan.
- 16.10. A storm water management plan to be implemented during the construction and operation of the facility. The plan must ensure compliance with applicable regulations and prevent off-site migration of contaminated storm water or increased soil erosion. The plan must include the construction of appropriate design measures that allow surface and subsurface movement of water along drainage lines so as not to impede natural surface and subsurface flows. Drainage measures must promote the dissipation of storm water run-off.
- 16.11. An erosion management plan for monitoring and rehabilitating erosion events associated with the facility. Appropriate erosion mitigation must form part of this plan to prevent and reduce the risk of any potential erosion.
- 16.12. An effective monitoring system to detect any leakage or spillage of all hazardous substances during their transportation, handling, use and storage. This must include precautionary measures to limit the possibility of oil and other toxic liquids from entering the soil or storm water systems.
- 16.13. A fire management plan to be implemented during the construction and operational phases.
- 16.14. Measures to protect hydrological features such as streams, rivers, pans, wetlands, dams and their catchments, and other environmental sensitive areas from construction impacts including the direct or indirect spillage of pollutants.
- 16.15. An environmental sensitivity map indicating environmental sensitive areas and features identified during the EIA process.
- 16.16. A map combining the final layout map superimposed (overlain) on the environmental sensitivity map. This map must reflect the proposed location of the turbine as stated in the EIA and this authorisation.
17. The final amended EMPr (once approved) must be implemented and strictly enforced during all phases of the project. It shall be seen as a dynamic document and shall be included in all contract documentation for all phases of the development when approved.
18. Changes to the approved EMPr must be submitted in accordance to the EIA Regulations applicable at the time.
19. The Department reserves the right to amend the approved EMPr should any impacts that were not anticipated or covered in the EIA be discovered.

#### **Frequency and process of updating the EMPr**

20. The EMPr must be updated where the findings of the environmental audit reports, contemplated in Condition 28 below, indicate insufficient mitigation of environmental impacts associated with the

undertaking of the activity, or insufficient levels of compliance with the environmental authorisation or EMPr.

21. The updated EMPr must contain recommendations to rectify the shortcomings identified in the environmental audit report.
22. The updated EMPr must be submitted to the Department for approval together with the environmental audit report, as per Regulation 34 of GN R. 982. The updated EMPr must have been subjected to a public participation process, which process has been agreed to by the Department, prior to submission of the updated EMPr to the Department for approval.
23. In assessing whether to grant approval of an EMPr which has been updated as a result of an audit, the Department will consider the processes prescribed in Regulation 35 of GN R.982. Prior to approving an amended EMPr, the Department may request such amendments to the EMPr as it deems appropriate to ensure that the EMPr sufficiently provides for avoidance, management and mitigation of environmental impacts associated with the undertaking of the activity.
24. The holder of the authorisation may apply for an amendment of an EMPr, if such amendment is required before an audit is required. The amendment process is prescribed in Regulation 37 of GN R.982. The holder of the authorisation must request comments on the proposed amendments to the impact management outcomes of the EMPr or amendments to the closure objectives of the closure plan from potentially interested and affected parties, including the competent authority, by using any of the methods provided for in the Act for a period of at least 30 days.

## **Monitoring**

25. The holder of the authorisation must appoint an experienced independent Environmental Control Officer (ECO) for the construction phase of the development that will have the responsibility to ensure that the mitigation/rehabilitation measures and recommendations referred to in this environmental authorisation are implemented and to ensure compliance with the provisions of the approved EMPr.
  - 25.1. The ECO must be appointed before commencement of any authorised activities.
  - 25.2. Once appointed, the name and contact details of the ECO must be submitted to the *Director: Compliance Monitoring* of the Department.
  - 25.3. The ECO must keep record of all activities on site, problems identified, transgressions noted and a task schedule of tasks undertaken by the ECO.
  - 25.4. The ECO must remain employed until all rehabilitation measures, as required for implementation due to construction damage, are completed and the site is ready for operation.

### **Recording and reporting to the Department**

26. All documentation e.g. audit/monitoring/compliance reports and notifications, required to be submitted to the Department in terms of this environmental authorisation, must be submitted to the *Director: Compliance Monitoring* of the Department.
27. The holder of the environmental authorisation must, for the period during which the environmental authorisation and EMPr remain valid, ensure that project compliance with the conditions of the environmental authorisation and the EMPr are audited, and that the audit reports are submitted to the *Director: Compliance Monitoring* of the Department.
28. The frequency of auditing and of submission of the environmental audit reports must be as per the frequency indicated in the EMPr, taking into account the processes for such auditing as prescribed in Regulation 34 of GN R. 982.
29. The holder of the authorisation must, in addition, submit environmental audit reports to the Department within 30 days of completion of the construction phase (i.e. within 30 days of site handover) and a final environmental audit report within 30 days of completion of rehabilitation activities.
30. The environmental audit reports must be compiled in accordance with Appendix 7 of the EIA Regulations, 2014 and must indicate the date of the audit, the name of the auditor and the outcome of the audit in terms of compliance with the environmental authorisation conditions as well as the requirements of the approved EMPr.
31. Records relating to monitoring and auditing must be kept on site and made available for inspection to any relevant and competent authority in respect of this development.

### **Notification to authorities**

32. A written notification of commencement must be given to the Department no later than fourteen (14) days prior to the commencement of the activity. Commencement for the purposes of this condition includes site preparation. The notice must include a date on which it is anticipated that the activity will commence, as well as a reference number.

### **Operation of the activity**

33. A written notification of operation must be given to the Department no later than fourteen (14) days prior to the commencement of the activity operational phase.

## Site closure and decommissioning

34. Should the activity ever cease or become redundant, the holder of the authorisation must undertake the required actions as prescribed by legislation at the time and comply with all relevant legal requirements administered by any relevant and competent authority at that time.

## Specific conditions

### Turbines position

35. Up to 29 wind turbines are approved.
36. All wind turbines must avoid all areas designated as "no-go" areas as well as their buffers.
37. The final placement of turbines must follow a micro siting procedure involving a walk-through and identification of any sensitive areas by ecological, avifaunal, bat, surface water and heritage specialists.
38. Exclusion of sensitive ecological, avifaunal, bat, surface water and heritage areas from construction activities must inform micro siting of all development activities.

### Avifauna and bats

39. Monitoring of breeding status of Martial Eagles should be conducted in all breeding seasons prior to and during construction.
40. During the operation phase, if Blue Crane turbine or power line collision fatalities occur as a result of livestock feeding, either farmers must be restricted from feeding between 200m-300m from turbines and power lines or feeding points must be covered or obstructed in some way that prevents the birds from easily feeding from them.
41. A 6km no-go buffer around the Martial Eagle nest must be respected.
42. Prior to construction, an avifaunal specialist must conduct a site walkthrough, covering the final road and powerline routes as well as the final turbine positions, to identify any nests/breeding/roosting activity of priority species, as well as any additional sensitive habitats. The results thereto must inform the final construction schedule in close proximity to that specific area, including reducing construction time, scheduling activities around avian breeding and/or movement schedules, and lowering levels of associated noise.
43. During operational monitoring, if above threshold mortalities are recorded, then the following preliminary mitigation schedule must be consulted to advise on the mitigation to be applied at identified turbines at selected high risk bat activity times and weather conditions:

**Preliminary mitigation schedule**

Peak activity (times to implement curtailment/ mitigation)	1 February – 30 April from the time of sunset to 23:00
Environmental conditions in which to implement curtailment/ mitigation	Wind speed below 4m/s and Temperature above 17°C
Peak activity (times to implement curtailment/ mitigation)	1 – 30 September from the time of sunset – 02:00
Environmental conditions in which to implement curtailment/ mitigation	Wind speed below 7.5m/s and Temperature above 13°C

44. Curtailment must be applied initially to all turbines at the start of operation at Level 3 of the mitigation scale (Ninety-degree feathering of blades below manufacturer's cut-in speed so it is exactly parallel to the wind direction as to minimise free-wheeling blade rotation as much as possible without locking the blades).
45. A construction and operational avifauna and bat monitoring plan must be developed and implemented according to the latest BirdLife South Africa/Endangered Wildlife Trust: Best practice guidelines for avian monitoring and impact mitigation at proposed wind energy development sites in Southern Africa and the latest South African Bat Assessment Advisory Panel's (SABAAP) guidelines.
46. As an absolute minimum, avifauna and bat monitoring, to survey impacts resulting from the infrastructure on the bird communities with focus on assessing the displacement and disturbance effects of the development on the bird communities, as well as bird collisions and continue to gather information on the bird communities present in the area and monitor the effectiveness of the mitigation measures, must occur during the construction period and continue for at least three years during the operation of the facility. The results of this monitoring must be made available to the Department of Environmental Affairs (DEA), Birdlife South Africa (BLSA) and the South African Bat Assessment Advisory Panel (SABAAP) and must further advise the EMPr where necessary.
47. The results of the pre-construction bird and bat monitoring assessments including all recommendations proposed by the reports dated March 2019, must inform the final layout and the construction schedule of the facility.
48. The facility must be designed in a manner that prevents infrastructure components from being used as perching or roosting substrates by birds and bats, as such is prohibited.
49. The holder of this environmental authorisation must restrict the construction activities to the footprint area. No access to the remainder of the property is allowed.

50. Anti-collision devices such as bird flappers must be installed where powerlines cross avifaunal corridors (e.g. grasslands, rivers, wetlands, and dams). The input of an avifaunal specialist must be obtained for the fitting of the anti-collision devices onto specific sections of the line once the exact positions of the towers have been surveyed and pegged. Additional areas of high sensitivity along the preferred alignment must also be identified by the avifaunal specialist for the fitment of anti-collision devices. These devices must be according to Eskom's Transmission and EWT's Guidelines.
51. A pre-construction walk through of the approved powerline alignment and turbine positions by a bat specialist, avifaunal specialist and ecologist, must be conducted to ensure that the micro-siting of the turbines, pylons and powerline alignments have the least possible impact, there are no nest sites of priority species on or close to the construction corridor and all protected plant species impacted are identified.

Vegetation, wetlands and water resources

52. No development/infrastructure are allowed within the No-Go areas.
  53. All internal powerline/cables must follow internal access roads.
  54. The 'no-go' areas of the development property must be clearly demarcated and must be excluded from the final layout plan.
  55. An aquatic specialist must conduct an in-depth site walkover prior to the construction phase commencing, after the proposed construction footprint has been confirmed and demarcated. This is to assess the footprint for any freshwater habitats, allowing for slight alterations in the footprint, to prevent any impacts on the freshwater habitats due to the actions conducted during the construction phase.
  56. Relevant permits must be obtained from relevant authorities for any removal or destruction of Threatened or Protected Species (TOPs).
  57. Before the clearing of the site, the appropriate permits must be obtained from the Department of Agriculture, Forestry and Fisheries (DAFF) for the removal of plants listed in the National Forest Act and from the relevant provincial departments for the destruction of species protected in terms of the specific provincial legislation. Copies of the permits must be kept by the ECO.
  58. Construction activities must be restricted to demarcated areas to restrict the impact on sensitive environmental features.
  59. All areas of disturbed soil must be reclaimed using only indigenous grass and shrubs. Reclamation activities shall be undertaken according to the rehabilitation plan to be included in the final EMPr.
  60. Topsoil from all excavations and construction activities must be salvaged and reapplied during reclamation.
  61. No exotic plants must be used for rehabilitation purposes; only indigenous plants of the area must be utilised.
-

62. No activities will be allowed to encroach into a water resource without a Water Use License being in place from the Department of Water and Sanitation.
  63. Cleared alien vegetation must not be dumped on adjacent intact vegetation during clearing but must be temporarily stored in a demarcated area.
  64. Removal of alien invasive species or other vegetation and follow-up procedures must be in accordance with the Conservation of Agricultural Resources Act, 1983 (Act 43 of 1983).
  65. Contractors and construction workers must be clearly informed of the no-go areas.
  66. Where roads pass right next to major water bodies, provisions must be made for fauna to pass under the roads by using culverts or similar structures.
  67. Bridge design must be such that it minimises impact to riparian areas with minimal alterations to water flow and must allow the movement of fauna and flora.
  68. The final development area should be surveyed for species suitable for search and rescue, which should be trans-located prior to the commencement of construction.
  69. Electric fencing should not have any strands within 30cm of the ground, which should be sufficient to allow smaller mammals, reptiles and tortoises to pass through, but still remain effective as a security barrier.
  70. Disturbed areas must be rehabilitated as soon as possible after construction with locally indigenous plants to enhance the conservation of existing natural vegetation on site.
  71. Wetlands, rivers and river riparian areas must be treated as "no-go" areas and demarcated as such. No vehicles, machinery, personnel, construction material, fuel, oil, bitumen or waste must be allowed into these areas without the express permission of and supervision of the ECO, except for rehabilitation work in these areas.
  72. Workers must be made aware of the importance of not destroying or damaging the vegetation along rivers and wetland areas and this awareness must be promoted throughout the construction phase.
  73. Freshwater ecosystems located in close proximity to the construction areas must be inspected on a regular basis (but especially after rainfall) by the ECO for signs of disturbance, sedimentation and pollution from construction activities. If signs of disturbance, sedimentation or pollution are noted, immediate action must be taken to remedy the situation and, if necessary, a freshwater ecologist must be consulted for advice on the most suitable remediation measures.
  74. No discharge of effluents or polluted water must be allowed into any rivers or wetland areas.
  75. If construction areas are to be pumped of water (e.g. after rains), this water must be pumped into an appropriate settlement area, and not allowed to flow into any rivers or wetland areas.
  76. Workers must be made aware of the importance of not polluting rivers or wetlands and of not undertaking activities that could result in such pollution, and this awareness must be promoted throughout the construction phase.
-

### Roads and transportation

77. Existing road infrastructure must be used as far as possible for providing access to the proposed turbine positions. Where no road infrastructure exists, new roads must be placed within existing disturbed areas or environmental conditions must be taken into account to ensure that minimum amount of damage is caused to natural habitats.
78. Signs must be placed along construction roads to identify speed limits, travel restrictions, and other standard traffic control information. To minimize impacts on local commuters, consideration must be given to limiting construction vehicles travelling on public roadways during the morning and late afternoon commute time.
79. Internal access roads must be located to minimize stream crossings. All structures crossing streams must be located and constructed such that they do not decrease channel stability or increase water velocity.
80. A designated access to the site must be created and clearly marked to ensure safe entry and exit.
81. Signage must be erected at appropriate points warning of turning traffic and the construction site.
82. Necessary permits must be obtained for the oversized construction vehicles to transport turbine components.
83. Construction vehicles carrying materials to the site must avoid using roads through densely populated built-up areas so as not to disturb existing retail and commercial operations.
84. Signs must be placed along construction roads to identify speed limits, travel restrictions, and other standard traffic control information to minimize impacts on possible faunal species.
85. Road borders must be regularly maintained to ensure that vegetation remains short and that they therefore serve as an effective firebreak.
86. Roads must be designed such that changes to surface water runoff are avoided and erosion is not initiated.
87. All construction vehicles must adhere to a low speed limit to avoid collisions with susceptible species.

### Noise

88. Routine noise measurements must be conducted during the operation of the facility and a complaints register must be opened and made available to affected parties and to the Department on request.
89. The holder of this authorisation must ensure that the construction staff working in areas where the 8-hour ambient noise levels exceed 75dBA wear ear protection equipment.
90. The holder of this authorisation must ensure that all equipment and machinery are well maintained and equipped with silencers.

91. The holder of this authorisation must provide a prior warning to the community when a noisy activity e.g. blasting is to take place.
92. Construction staff must be trained in actions to minimise noise impacts.
93. The holder of this authorisation must ensure that the National Noise Control Regulations and SANS10103:2008 are adhered to and measures to limit noise from the work site are implemented.

#### Visual resources

94. The holder of this authorisation must reduce visual impacts during construction by minimising areas of surface disturbance, controlling erosion, using dust suppression techniques and restoring exposed soil as closely as possible to their original contour and vegetation.
95. A lighting engineer must be consulted to assist in the planning and placement of light fixtures in order to reduce visual impacts associated with glare and light trespass.
96. Lighting of main structures (turbines) and ancillary buildings must be designed to minimise light pollution without compromising safety, and turbines must be lit according to Civil Aviation Regulations.
97. Signage on or near wind turbines must be avoided unless they serve to inform the public about wind turbines and their function.
98. Commercial messages and graffiti on turbines are prohibited.

#### Human health and safety

99. A health and safety programme must be developed to protect both workers and the general public during construction, operation and decommissioning of the energy facility. The programme must establish a safety zone for wind turbines from residences and occupied buildings, roads, right-of-ways and other public access areas that is sufficient to prevent accidents resulting from the operation of the wind turbines.
100. Potential interference with public safety communication systems (e.g. radio traffic related to emergency activities) must be avoided.
101. The holder of this authorisation must obtain approval from the South Africa Civil Aviation Authority that the wind facility will not interfere with the performance of aerodrome radio Communication, Navigation and Surveillance (CNS) equipment, especially the radar, prior to commencement of the activity. A copy of the approval must be kept on site by the ECO.
102. The holder of this authorisation must ensure that the operation of the wind facility complies with the relevant communication regulations or guidelines relating to electromagnetic interference, e.g. microwave, radio and television transmissions.

103. The holder of this authorisation must obtain approval from the South Africa Weather Services (WeatherSA) that the energy facility will not interfere with the performance of their equipment, especially radar, prior to commencement of the activity. A copy of the approval must be kept on site by the ECO.
104. The holder of this authorisation must train safety representatives, managers and workers in workplace safety. The construction process must be compliant with all safety and health measures as prescribed by the relevant act.
105. Liaison with land owners/farm managers must be done prior to construction in order to provide sufficient time for them to plan agricultural activities.
106. No unsupervised open fires for cooking or heating must be allowed on site.

#### Hazardous materials and waste management

107. Areas around fuel tanks must be bunded or contained in an appropriate manner as per the requirements of SABS 089:1999 Part 1.
  108. Leakage of fuel must be avoided at all times and if spillage occurs, it must be remedied immediately.
  109. Hazardous waste such as bitumen, oils, oily rags, paint tins etc. must be disposed of at an approved waste landfill site licensed to accept such waste.
  110. No dumping or temporary storage of any materials may take place outside designated and demarcated laydown areas, and these must all be located within areas of low environmental sensitivity.
  111. Hazardous substances must not be stored where there could be accidental leakage into surface or subterranean water.
  112. Hazardous and flammable substances must be stored and used in compliance to the applicable regulations and safety instructions. Furthermore, no chemicals must be stored nor may any vehicle maintenance occur within 350m of the temporal zone of wetlands, a drainage line with or without an extensive floodplain or hillside wetlands.
  113. Temporary bunds must be constructed around chemical storage to contain possible spills.
  114. Spill kits must be made available on-site for the clean-up of spills.
  115. An integrated waste management approach must be implemented that is based on waste minimisation and must incorporate reduction, recycling and re-use options where appropriate. Where solid waste is disposed of, such disposal shall only occur at a landfill licensed in terms of section 20(b) of the National Environment Management Waste Act, 2008 (Act 59 of 2008).
  116. The holder of this authorisation must provide sanitation facilities within the construction camps and along the road so that workers do not pollute the surrounding environment. These facilities must be removed from the site when the construction phase is completed as well as associated waste to be disposed of at a registered waste disposal site.
-

117. The holder of this authorisation must take note that no temporary site camps will be allowed outside the footprint of the development area as the establishment of such structures might trigger a listed activity as defined in the Environmental Impact Assessment Regulations, 2014 as amended.

#### Excavation and blasting activities

118. Underground cables and internal access roads must be aligned as much as possible along existing infrastructure to limit damage to vegetation and watercourses.
119. Foundations and trenches must be backfilled with originally excavated materials as much as possible. Excess excavation materials must be disposed of only in approved areas or, if suitable, stockpiled for use in reclamation activities.
120. Borrow materials must be obtained only from authorised and permitted sites. Permits must be kept on site by the ECO.
121. Anti-erosion measures such as silt fences must be installed in disturbed areas.

#### Air emissions

122. Dust abatement techniques must be used before and during surface clearing, excavation, or blasting activities.
123. Appropriate dust suppression techniques must be implemented on all exposed surfaces during periods of high wind. Such measures may include wet suppression, chemical stabilisation, the use of a wind fence, covering surfaces with straw chippings and re-vegetation of open areas.

#### Historical / cultural / paleontological resources

124. Should construction activities be within 100 metres from archaeological sites and historical sites, the sites must be demarcated and fenced off.
125. If concentrations of archaeological heritage material, fossils and human remains are uncovered during construction, all work must cease immediately and be reported to the South African Heritage Resources Agency (SAHRA) so that a systematic and professional investigation / excavation can be undertaken.
126. Construction managers/foremen must be informed before construction starts of the possible types of heritage sites and cultural material that may be encountered and the procedures to follow when they find sites.
127. All buffers and no-go areas stipulated in the EIAR must be adhered to for the facility, all roads and powerlines.
128. All construction and maintenance crew and vehicles (except small vehicles which may use existing farm tracks) must be kept out of the buffer zones.
-

129. The final layout must be shown to the appointed archaeologist before implementation to confirm that all significant heritage resources have been adequately protected.

### General

130. The recommendations of the EAP in the EIAR dated June 2019 and the specialist studies attached must be adhered to. In the event of any conflicting mitigation measures and conditions of the Environmental Authorisation, the specific condition of this Environmental Authorisation will take preference.
131. A copy of this environmental authorisation, the audit and compliance monitoring reports, and the approved EMPr, must be made available for inspection and copying-
- 131.1. at the site of the authorised activity;
  - 131.2. to anyone on request; and
  - 131.3. where the holder of the environmental authorisation has a website, on such publicly accessible website.
132. National government, provincial government, local authorities or committees appointed in terms of the conditions of this authorisation or any other public authority shall not be held responsible for any damages or losses suffered by the holder of the authorisation or his/her successor in title in any instance where construction or operation subsequent to construction be temporarily or permanently stopped for reasons of non-compliance by the holder of the authorisation with the conditions of authorisation as set out in this document or any other subsequent document emanating from these conditions of authorisation.

Date of environmental authorisation: 23/09/2019

  
Mr Sabelo Malaza

Chief Director: Integrated Environmental Authorisations  
Department of Environmental Affairs

## Annexure 1: Reasons for Decision

### 1. Information considered in making the decision

In reaching its decision, the Department took, *inter alia*, the following into consideration -

- a) The listed activities as applied for in the application form received on 10 October 2018.
- b) The information contained in the EIAr dated June 2019.
- c) The comments received from SAHRA, SANRAL, Eskom, SENTEC, CAA, the Eastern Cape Department of Economic Development, Environmental Affairs & Tourism, the South African Astronomical Observatory, the Eastern Cape Provincial Heritage Resources Authority, DAFF, DWS, South African Bat Assessment Association and interested and affected parties as included in the EIAr dated June 2019.
- d) Mitigation measures as proposed in the EIAr and the EMPr.
- e) The information contained in the specialist studies contained within the appendices of the EIAr dated June 2019 and as appears below:

Title	Prepared by	Date
Ecological Impact Assessment	3Foxes Biodiversity Solutions	February 2019
Aquatic Impact Assessment	Scherman Colloty & Associates	February 2019
Avifaunal Impact Assessment	Wild Skies Ecological Services	March 2019
Bat Impact Assessment	Animalia Consultants	March 2019
Agricultural and Soils Impact Assessment	Johann Lanz	March 2019
Socio-Economic impact assessment	Urban-Econ Development Economists	April 2019
Archaeological Impact Assessment	Dr. Peter Nilssen	February 2019
Noise and Shadow-Flicker Study	3E Renewable Energy Services	March 2019
Visual Impact Assessment	Quinton Lawson	February 2019
Traffic Impact Assessment	Athol Schwarz	March 2019
Wake Effect Study	Africoast Energy	March 2019
EMPr	Aurecon SA	April 2019

## **2. Key factors considered in making the decision**

All information presented to the Department was taken into account in the Department's consideration of the application. A summary of the issues which, in the Department's view, were of the most significance is set out below.

- a) The findings of all the specialist studies conducted and their recommended mitigation measures.
- b) The need for the proposed project stems from the provision of electricity to the national grid.
- c) The EIAr dated June 2019 identified all legislation and guidelines that have been considered in the preparation of the EIAr.
- d) The location of the proposed wind energy facility.
- e) The methodology used in assessing the potential impacts identified in the EIAr dated June 2019 and the specialist studies have been adequately indicated.
- f) A sufficient public participation process was undertaken and the applicant has satisfied the minimum requirements as prescribed in the EIA Regulations, 2014 for public involvement.

## **3. Findings**

After consideration of the information and factors listed above, the Department made the following findings -

- a) The identification and assessment of impacts are detailed in the EIAr dated June 2019 and sufficient assessment of the key identified issues and impacts have been completed.
- b) The procedure followed for impact assessment is adequate for the decision-making process.
- c) The information contained in the EIAr dated June 2019 is deemed to be accurate and credible.
- d) The findings of the site inspection held on 17 April and 18 July 2019.
- e) The proposed mitigation of impacts identified and assessed adequately curtails the identified impacts.
- f) EMPr measures for the pre-construction, construction and rehabilitation phases of the development were proposed and included in the EIAr and will be implemented to manage the identified environmental impacts during the construction phase.

In view of the above, the Department is satisfied that, subject to compliance with the conditions contained in the environmental authorisation, the authorised activities will not conflict with the general objectives of integrated environmental management laid down in Chapter 5 of the National Environmental Management Act, 1998 and that any potentially detrimental environmental impacts resulting from the

authorised activities can be mitigated to acceptable levels. The environmental authorisation is accordingly granted.